

मुख्य अग्निशमन अधिकारी  
**OFFICE OF THE CHIEF FIRE OFFICER**  
अण्डमान तथा निकोबार द्वीप समूह  
**Andaman and Nicobar Islands**

Clearance Number : **FS/FCC/2024/1301**

Port Blair dated **16/03/2024**

**FIRE CLEARANCE CERTIFICATE**

This is to certify that the **IQRA PUBLIC SCHOOL** situated at **Opp. to BSNL Exchange, Wimberlygunj, South Andaman, KANYAPURAM, FERRARGUNJ** bearing Survey No. **122,123/1,123/2** have complied with the fire prevention and fire safety requirements in accordance with NBC guidelines and verified by Fire Brigade Officer on **12/03/2024** and the school is safe from fire safety point of view for a period of one (1) year from the date of issue of this FCC, subject to compliance of specific conditions as appended:-

Note:- Conditions for the validity of Fire Clearance Certificate (FCC)

1. The school consists of four separate blocks. Three blocks are having two (G+1) floors and fourth block is having four (Basement+G+2) floors (No classrooms/activity are functioning at fourth block except ground floor). The FCC is for functioning of classes from Nursery to 10th standard.
2. Students of Classes from Nursery to 1st Standard shall be located at ground floor only and the Class 2 students shall be located not above first floor.
3. Building stability and satisfactory electrical installation to be ascertained from concerned agency.
4. FCC shall stand null and void if there is any violation in existing firefighting arrangements.
5. The school building is also not as per approved building plan. FCC may not be treated in any case for regularization of unauthorized construction, if any or violation in building plan.
6. All fire safety arrangements provided therein shall be maintained in good working conditions at all time and all staff members shall be well acquainted to

operate all fire safety equipments.

7. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.

8. All staff should be trained in firefighting. Trained firefighting staff should be available during school hours.

9. Any deviation with regard to construction etc. shall be verified by the concerned building sanctioning authority.

10. Occupant load in class room should be calculated at not less than 4 m<sup>2</sup> per students.

11. No combustible material should be used for construction of school building.

12. No cooking should be done within the school building.

13. The firefighting equipment register, mock drill register and staff training register should be updated regularly.

Copy to:-

1. The Director of Education, P/Blair
2. The Panchayat Secretary, GP W/gunj



*[Handwritten signature]*

**Inspector Fire Brigade (Port Blair)**  
Andaman and Nicobar Islands

**To**

ABDUL RASHEED  
Opp. to BSNL Exchange, Wimberlygunj, South Andaman  
KANYAPURAM  
FERRARGUNJ  
SOUTH ANDAMAN - 744206

*[Handwritten signature]*

**Manager**  
**IQRA Public School**  
**Wimberlygunj**

*[Handwritten signature]*

**PRINCIPAL**  
**IQRA PUBLIC SCHOOL**  
Wimberlygunj