

Print

मुख्य अग्निशमन अधिकारी  
**OFFICE OF THE CHIEF FIRE OFFICER**  
 अण्डमान तथा निकोबार द्वीप समूह  
**Andaman and Nicobar Islands**

Clearance Number : **FS/FCC/2025/1791**Port Blair dated **18/10/2025**

**FIRE CLEARANCE CERTIFICATE**

This is to certify that the **IQRA PUBLIC SCHOOL** situated at **Opp. to BSNL Exchange, Wimberlygunj, South Andaman, KANYAPURAM, FERRARGUNJ** bearing Survey No. **122,123/1,123/2** has been inspected and there is "**NO OBJECTION**" from fire safety point of view. The First Aid Fire Fighting arrangements in the **School** are found satisfactory and reliable for a period of one (1) year from the date of issue of this FCC, subject to no change is effected in the existing fire fighting arrangements.

Note:- Conditions for the validity of Fire Clearance Certificate (FCC)

1. The school comprises four separate blocks. Out of these, three blocks consist of two floors each (G+1), and the fourth block consists of Basement + Ground + 2 floors. As per the undertaking provided by the Principal of IQRA Public School, the fourth block is not being used for any academic or non-academic activities. Only the three (G+1) blocks are being utilized for school functioning. The Fire Clearance Certificate (FCC) has been issued for the operation of classes from Nursery to 10th Standard.
2. Students of Classes from Nursery to 1st Standard shall be located at ground floor only and the Class 2 students shall be located not above first floor.
3. Building stability and satisfactory electrical installation to be ascertained from concerned agency.
4. FCC shall stand null and void if there is any violation in existing firefighting arrangements.
5. The school building is also not as per approved building plan. FCC may not be treated in any case for regularization of unauthorized construction, if



any or violation in building plan.

6. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
7. All staff should be trained in firefighting. Trained firefighting staff should be available during school hours.
8. Means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
9. Occupant load in class room should be calculated at not less than 4 m<sup>2</sup> per students.
10. No combustible material should be used for construction of school building.
11. No cooking should be done within the school building.
12. The firefighting equipment register, mock drill register and staff training register should be updated regularly.

Copy to:-

1. The Panchayat Secretary, Gram Panchayat Wimberlygunj, for kind information
2. The DEO, Wimberlygunj for kind information



*[Handwritten signature]*

Inspector Fire Brigade  
(Port Blair)  
Andaman and Nicobar  
Islands

To

ABDUL RASHEED  
Opp. to BSNL  
Exchange, Wimberlygu  
nj, South Andaman  
KANYAPURAM  
FERRARGUNJ  
SOUTH ANDAMAN -  
744206

*[Handwritten signature]*  
PRINCIPAL  
IQRA PUBLIC SCHOOL  
Wimberlygunj